

CENTRAL POWER RESEARCH INSTITUTE



CPRI

TEST REPORT

Test Report Number : CPRIPLSTNCMISC21T0321 **Date:** 08 November 2021

Name and Address of the Customer : M/s. Gayatri Engineers,
34 Bhagirath Industrial Estate, Part-1, Gulabnagar
Near Swastika Cross Road, Amriwadi,
Ahmedabad, Gujarat-380 026

Name and Address of the Manufacturer : M/s. Gayatri Engineers,
34 Bhagirath Industrial Estate, Part-1, Gulabnagar
Near Swastika Cross Road, Amriwadi,
Ahmedabad, Gujarat-380 026


Particulars of sample tested : 415 V, 250A, LT Panel

Type : Outdoor
Description of test sample : 415 V, 250A, LT Panel
Serial Number : GE/IP65/001
Number of samples tested : One
Date(s) of Test(s) : 08 September 2021 & 09 September 2021.
CPRI Sample code Number(s). : STNCMISC21S0265
Particulars of tests conducted : Degree of Protection IP-65

Test in accordance with : As per customer's requirement.
Standard/specification :
Sampling Plan : Nil
Customer's Requirement : As per Cl. 10.3 of IS/IEC 61439 (Part-1):2011.
Deviations, if any : Test was conducted on panel with TP MCCB and busbars only.

Name of the witnessing persons :
Customer's representative : Mr. Ravi Jain
Other than customer's representative : Nil
Test subcontracted with address of the laboratory : None

Documents constituting this report (in words) :
Number of Sheets : Six
Number of Oscillogram(s) : Nil
Number of Graph(s) : Nil
Number of Photograph(s) : One
Number of Test Circuit Diagram(s) : Nil
Number of Drawing(s) : One


(Manoj Hirani)
Test Engineer




(Sarita Dongre)
Head of Division
Reviewed and Authorized By